

**ADDENDUM NUMBER 1
23 December 2008**

NORTHUMBERLAND FARMERS MARKET PAVILION

**NORTHUMBERLAND COUNTY
72 MONUMENT PLACE
P.O. BOX 129
HEATHSVILLE, VIRGINIA**

The drawings and specifications for the above project are hereby amended, revised or changed as follows:

1. *All convenience outlets are required to be ground-fault protected.*
2. *Drawings Number;2,3,5 and 6, change all references to 4"x4" treated posts to 6"x6" treated posts and change PVC covers to 6"x6".*
3. *Change Specifications page 00010-3; Alternate Number 2, to read, "delete all 6 inch white PVC column covers."*

Willard E. Gwilliam FAIA
7830 Sunset Drive
Hayes, Va. 23072
804-815-1612

NOTE: Contractors are advised to note receipt of this Addendum on their Bid Form in the appropriate place provided.