

Addendum No.1
for the
Northumberland County High/Middle School Sanitary
Treatment Modification Project

Prepared For
Northumberland County
72 Monument Place
Heathsville, VA 22473



Prepared by
C. Robert L. Mangrum, P.E., BCEE
Mangrum Consulting & Design
1500 Clayton Avenue
Lynchburg, VA 24503

Addendum Date: January 9, 2024

This Addendum No. 1, dated January 9, 2024 amends or supplements the Contract Documents titled Northumberland County High/Middle School Sanitary Treatment Modification Project Dated November 14, 2023 as indicated below:

Changes to Drawings:

Item 1: See Questions and Responses.

Changes to Project Manual:

Item 1: See Questions and Responses.

Questions & Responses:

Question 1: The drawings require all the precast tanks to be H2O Loading, is this correct ?

Response 1: The precast tanks DO NOT require H2O Loading.

Question 2: On drawing E-001 in the process control narrative it is stated that the PLC shall store certain data for 90 days. I need to know at what interval this data needs to be collected I.E. every hour, once a day, second by second.

Response 2: Flow meter data to be collected every 15 seconds; Level data to be collected every 15 minutes.

Question 3: Can the bid date be moved ?

Response 3: Yes, this addendum moves the bid date from Jan 11, 2024 at 2:00 PM to January 18, 2024 at 2:00 PM. Please note the address for delivery of bids (and opening) is: Old Courthouse Complex located at 72 Monument Place, Heathsville VA 22473.

Attachments

None.

END OF ADDENDUM NO. 1